

English Version

OFFICE : EXECUTIVE ENGINEER, PROVINCIAL DIVISION, PWD B&R BRANCH, FARIDKOT, PIN CODE : 151203

e-mail id : eepdfdtowdpb@gmail.com

telephone 01639-250178

To

Principal
Major Ajaib Singh Convent School,
Jiwan Wala (Distt. Faridkot)


No. 2698

Dated 24-05-2022.

Sub:- To issue Building Safety Certificate for the year 2022-23

On the subject cited the building safety is being issued on the following terms and on the basis of report of Sub Divisional Engineer B& R Branch Faridkot and Fire Services Faridkot

1. The building of the school is safe on the basis visual.
2. The building safety certificate for the year 2022-23 is concerned with this department is (valid upto 31-03-2023).
3. No concern of this letter/certificate with the ownership of the property.
4. No concern of this letter/certificate with the area of the plot of the school.
5. At the time of issuing the certificate by Fire Services, Faridkot vide their letter No. NOC No. 401-50959-Fire/37234 dated 06-05-2022 issued to the school and the concerned Fire Station Officer will be responsible.
6. No concern of this permission with the schedule road act.



Encl/ Certificate

Sd/-
Executive Engineer,
Provincial Division
PWD B&R Branch
Faridkot
Initial

Endst. No.

Dated

The copy of the above is Sub Divisional Engineer Const. Sub Division, B&R Faridkot with reference to their letter No. 100 dated 19-5-2022 for information and necessary action.

Sd/-
Executive Engineer,
Provincial Division
PWD B&R Branch
Faridkot

ATTESTED
TRUE TRANSLATED VERSION

VINOD KUMAR
NOTARY PUBLIC KOTKAPURA
App. by Govt. of India Regd. No.3114

26 MAY 2022

26/5/22

Manager
Major Ajaib Singh Educational &
Social Service Society, Jeonwala

Principal
Major Ajaib Singh Convent School
Jeonwala (Faridkot, Pb)

ਵੱਲ

ਪ੍ਰਿੰਸੀਪਲ,
ਮੇਜਰ ਅਜਾਇਬ ਸਿੰਘ ਕਾਨਵੈੱਟ ਸਕੂਲ,
ਜ਼ਿਉਣਵਾਲਾ (ਜਿਲ੍ਹਾ ਫਰੀਦਕੋਟ)।

ਨੰਬਰ: 2698


ਮਿਤੀ: 24.05.2022

ਵਿਸ਼ਾ:-

ਸਾਲ 2022-23 ਲਈ ਸਕੂਲ ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕਰਨ ਬਾਰੇ।

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਅਧੀਨ ਸਕੂਲ ਦੀ ਇਮਾਰਤ ਦਾ ਸੁਰੱਖਿਆ ਸਰਟੀਫਿਕੇਟ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਉਸਾਰੀ ਉਪ ਮੰਡਲ, ਭ ਤੇ ਮ ਸ਼ਾਖਾ, ਫਰੀਦਕੋਟ ਦੀ ਰਿਪੋਰਟ ਅਤੇ ਪੰਜਾਬ ਫਾਇਰ ਸਰਵਿਸਜ਼, ਫਰੀਦਕੋਟ ਵੱਲੋਂ ਜਾਰੀ ਸਰਟੀਫਿਕੇਟ ਨੂੰ ਮੁੱਖ ਰੱਖਦੇ ਹੋਏ ਹੇਠ ਲਿਖੀਆਂ ਸ਼ਰਤਾਂ ਦੇ ਆਧਾਰ ਤੇ ਜਾਰੀ ਕੀਤਾ ਜਾਂਦਾ ਹੈ:-

1. ਸਕੂਲ ਦੀ ਇਮਾਰਤ ਵਿਜ਼ੁਅਲ ਤੌਰ ਤੇ ਸੇਫ ਹੈ।
2. ਇਸ ਵਿਭਾਗ ਨਾਲ ਸਬੰਧਤ ਸੁਰੱਖਿਆ ਸਰਟੀਫਿਕੇਟ ਸਾਲ 2022-23 (ਅਪ-ਟੂ 31.03.2023) ਤੱਕ ਵੈਲਿਡ ਹੈ।
3. ਇਸ ਪੱਤਰ/ਸਰਟੀਫਿਕੇਟ ਦਾ ਸਕੂਲ ਦੀ ਜਗ੍ਹਾਂ ਦੀ ਮਲਕੀਅਤ ਨਾਲ ਕੋਈ ਸਬੰਧ ਨਹੀਂ ਹੈ।
4. ਇਸ ਪੱਤਰ/ਸਰਟੀਫਿਕੇਟ ਨਾਲ ਸਕੂਲ ਦੇ ਪਲਾਟ ਦੇ ਏਰੀਏ ਦਾ ਕੋਈ ਸਬੰਧ ਨਹੀਂ ਹੈ।
5. ਇਸ ਸਰਟੀਫਿਕੇਟ ਨੂੰ ਜਾਰੀ ਕਰਨ ਸਮੇਂ ਪੰਜਾਬ ਫਾਇਰ ਸਰਵਿਸਜ਼, ਫਰੀਦਕੋਟ ਵੱਲੋਂ ਆਪਣੇ **NOC No. 401-50959-Fire/37234** ਮਿਤੀ **06.05.2022** ਨਾਲ ਸਬੰਧਤ ਸਕੂਲ ਨੂੰ ਜੋ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕੀਤਾ ਗਿਆ ਹੈ, ਨੂੰ ਮੁੱਖ ਰੱਖਿਆ ਗਿਆ ਹੈ, ਜਿਸ ਦੀ ਜ਼ਿੰਮੇਵਾਰੀ ਸਬੰਧਤ ਫਾਇਰ ਸਟੇਸ਼ਨ ਅਫਸਰ ਦੀ ਹੋਵੇਗੀ।
6. ਇਸ ਮੰਨਜ਼ੂਰੀ ਦਾ ਸ਼ਡਿਊਲਡ ਰੋਡ ਐਕਟ ਨਾਲ ਕੋਈ ਸਬੰਧ ਨਹੀਂ ਹੈ।
ਨੱਥੀ/ ਸਰਟੀਫਿਕੇਟ


ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ,
ਪ੍ਰਾਂਤਕ ਮੰਡਲ, ਭ ਤੇ ਮ ਸ਼ਾਖਾ,
ਫਰੀਦਕੋਟ।

ਪਿੱਠ ਅੰਕਣ ਨੰਬਰ:

ਮਿਤੀ:

ਉਪਰੋਕਤ ਦਾ ਉਤਾਰਾ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਉਸਾਰੀ ਉਪ ਮੰਡਲ, ਭ ਤੇ ਮ ਸ਼ਾਖਾ, ਫਰੀਦਕੋਟ ਨੂੰ ਉਨ੍ਹਾਂ ਦੇ ਪੱਤਰ ਨੰ: 100
ਮਿਤੀ 19.05.2022 ਦੇ ਹਵਾਲੇ ਵਿੱਚ ਸੂਚਨਾ ਹਿੱਤ ਭੇਜਿਆ ਜਾਂਦਾ ਹੈ।


Manager
Major Ajaib Singh Educational &
Social Service Society, Jeonwala


ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ,
ਪ੍ਰਾਂਤਕ ਮੰਡਲ, ਭ ਤੇ ਮ ਸ਼ਾਖਾ,
ਫਰੀਦਕੋਟ।
Principal
Major Ajaib Singh Convent School
Jeonwala (Faridkot. Ph)

PROFORMA FOR SAFETY OF SCHOOL BUILDING

PART-1

(To be filled by the head of School/ Insitute)

- 1- Name of the School: *Majrat Ajaib Singh. Convent School, Jeonwala (Pak)*
- 2- Location: *V.P.O Jeonwala, Teh-Kotkapura Distt-Fazilkot*
- 3- Plot Area: *24 Kanal 12 Marla*
- 4- Plinth Area: *39 737 Sq.ft.*
- 5- Number of Storeys: *04*
- 6- Year of Construction of Building: *1992-93, 1994-95, 2002-03, 2005-06, 2014*
- 7- If the building has been constructed under the supervision of the qualified Engineer, the following details may be given
 - a) Name of the Engineer with qualification: *R.S Mawrya D.M. CIVIL*
 - b) Address of Engineer: *Engineer, Near Tota palao*
 - c) Set of Structural drawings used in the construction if available: *Fazilkot*
 - d) Name & Address of the architect with qualification:
- 8- Whether the building has been constructed for the purpose of:
 - a) School Yes/No
 - b) Residential Purpose and converted for use as a School Yes/No
- 9- Materials used for roofs
 - a) R.C.C Slaps/RBC Slabs Yes/No
 - b) R.S Joists & Battons Yes/No
 - c) Wooden joists&Battons Yes/No
- 10- Materials used for walls
 - a) Mud Mortar Yes/No
 - b) Cement Mortar Yes/No
 - c) Lime Mortar Yes/No
- 11- Flooring
 - a) Congregrate *(chip& Marble/Vitrified)* Yes/No
 - b) Terrazo Yes/No
 - c) Brick Paving Yes/No
- 12- A detailed drawing indicating dimensions of the rooms, alongwith size and location of doors and window (Attached) Yes/No
- 13- FOR FIRE SAFETY
 - a) Whether the width of the staircase is 1.5 mtr. Yes/No
 - b) Whether Portable fire extinguisher exists Yes/No
 - c) Whether School building is Free from inflamable & toxic material Yes/No
 - d) Whether cooking of food is done at a safe place Yes/No
 - e) Whether any Thatch or combustibile material has been used: Yes/No
- 14- Requirment for Fire Protecton Arrangements under NBC Part IV
(For building height less than 15 metre)
 - a) Whether House Real Provided Yes/No
 - b) Whether down corner provided Yes/No
 - c) Whether underground static water storage tank of copacity 50000 Ltr.(If covered area exceeds 1500 sqm) Yes/No

Fire Safety Certificate attached